



सत्यमेव जयते

**GOVT. OF ASSAM**  
**OFFICE OF THE DIRECTOR**  
**FIRE & EMERGENCY SERVICES, GUWAHATI**  
**ASSAM**



Form - G

UBIN : 281/53409/AMZPD0323Q/11/2022

UAIN : FIRNOCXII/2022/01589

**NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN APPLICATION FOR RENEWAL OF FIRE NOC UNDER ASSAM FIRE SERVICE RULE 1989 (FORM NO XII)**

**Hazard Category: Low Hazard**

This NOC is issued to **St Marry's Convent Public School** on **13/12/2022** with reference to Compliance Report No. **Nil** dated **01/11/2022**.

I hereby certify that the building as per description below at **Dag No. 196** , **Patta No. 128** , **Mouza Bongaigaon, Place Gaurav Nagar, Bagan Road** , **BONGAIGAON** has been inspected in respect of implementation of inbuilt Fire Fighting, Fire Prevention and Means of escape measures and is declared fit in respect of fire safety. The Fire & Emergency Services, Assam has no objection in its occupation/ utilization for the purpose of:

**DETAILS OF APPROVED OCCUPATION**

S. No.	Floor	Floor Area	Purpose of Utilization
1.	GROUND FLOOR	361.45 SQM	SCHOOL

THIS NOC IS VALID UP TO 12/12/2025

Place of issue: **GUWAHATI**

Director of Fire and Emergency  
Services,  
Guwahati, Assam

Date of issue : **13/12/2022**

(Subject to Conditions mentioned here under)

**CONDITIONS :**

1. There should not be any change of Trade for which this License has been issued.
2. There should not be any structural change in the building either horizontally or vertically. There should not also be any change in the existing arrangements.
3. The fire fighting equipments should be in serviceable condition at all time

4. Water reservoir should always be kept full up to brim
5. The entrance and exit and the water reservoir should always be free from any obstruction/projection.
6. The NOC is liable to be cancelled if the premises (for which the NOC is granted) when inspected are not found conforming to the description and condition under which this NOC is granted.

Director of Fire and Emergency  
Services,  
Guwahati, Assam



Note : This certificate is computer generated and does not require any Seal/Signaturo.

OFFICE OF THE  
BONGAIGAON FIRE & EMERGENCY SERVICES STATION  
BONGAIGAON::: ASSAM

Memo No. BNGN/F&ESS/61/148 /25

Dated: 02/03/2025

To,

Sri Chakra Dhar Das  
Marry's Convent Public School  
Ward No.24,Bongaigaon Town  
Dist: Bongaigaon(Assam)



**SUB:-RECOMENDATION FOR IMPLEMENTATION OF FIRE PROTECTION AND FIRE SAFETY MEASURES IN THE PROPOSED (G+2) EDUCATIONAL BUILDING(BLOCK A) IN THE NAME & STYLES "MARRY'S CONVENT PUBLIC SCHOOL" LOCATED AT WARD NO24,T R PHUKAN ROAD,BONGAIGAON TOWN, DIST: BONGAIGAON(ASSAM) ON LAND OF DAG NO.196 & PATTA NO.128.**

Ref: Your application on dated: 01/03/2025(ARN: FNESBNOCI/2025/00677)regarding NOC.

Sir/Madam,

With reference to the above, I have visited & inspected your premises in connection with Assessment for installation of Fire Fighting system and you are requested to implement following minimum Fire Prevention and Fire safety measures for safety of lives and properties.

***Before occupancy/utilization of the building, No Objection Certificate should be obtained from the Fire & Emergency Services, Assam.***

***After implementation of the following Fire safety measures Fire safety No Objection Certificate may be considered.***

**FIRE SAFTEY MEASURES RECOMENDATION AS PER N.B.C-2016 Part -IV:-**

1. One fire Point consist of 3(three) nos. sand bucket, 3(three) nos. water bucket, One ceiling hook & one fire beater should install in front of the premises.

2. Adequate No. of **Hose Reel Hose** should be provided in the building.

The length of hose reel should be such that no part of the premises remains unprotected when the hose reel is fully extended.

3.Down Comer system should be provide in the building.



4. **Terrace tank** of 10,000 Lts capacity & pump of 450 LPM should be provided for hose reel system.

5. **Manually operated electronic fire alarm system** should be provided in the building.

**6. Installation of portable Fire Extinguisher: -**

- i) Co<sub>2</sub> or DCP fire extinguisher of 4.5/5kg capacity should be installed in each floor of the buildings the extinguisher shall be so distributed over each floor area so that a person has to travel not more than 15 mtr to reach the nearest extinguisher.
- ii) Adequate No. of DCP and Co<sub>2</sub> extinguisher of 4/4.5 Kg and one AFFF extinguisher of 9 Ltrs capacity should be provided near carparking area.
- iii) Adequate No. of Co<sub>2</sub> extinguishers of 4.5 kg capacity should be provided near the electric panel board /switch gear room.

**N.B :- All fire extinguisher should be newly introduced Indian Standard as per IS 15683-2006.**

7. Electric wiring of the building should be conduit or concealed type.

8. To eliminate fire hazard, good housekeeping both inside and outside in the building shall be strictly maintained.

9. All staffs & students of the building should be trained to operate all the Firefighting system.

10. An Evacuation Plan should be prepared and describe all the staff& students of the premises to act accordingly in case of any emergency.

11. Any alteration/modification and change of the building will be informed immediately to the undersigned for taking necessary action.

12. Compliance reports on fire safety measure should be submitted to the undersigned for taking further necessary action.

13. Layout Plan showing location of fire safety installation should be submitted to undersigned for approval.

Yours faithfully,



Response Team Commander  
Bongaigaon Fire & Emergency Services Station  
Bongaigaon, Assam  
**Response Team Commander**  
**Bongaigaon Fire & Emergency**  
**Services Station**

Copy to:

1. The SPL DGP cum Director, Fire & Emergency Services, Assam, Guwahati for favour of information.
2. The District Commissioner, Bongaigaon, Assam, for kind information.

Yours faithfully,



Response Team Commander  
Bongaigaon Fire & Emergency Services Station  
Bongaigaon, Assam  
**Response Team Commander**  
**Bongaigaon Fire & Emergency**  
**Services Station**